

Appendix 1: Fire Safety Management Notice

1. Smoking is prohibited in the exhibition hall.
2. Open flames and open flame operations such as electric welding are prohibited in the exhibition hall.
3. It is prohibited to use iodine tungsten lamps, neon lamps and high-temperature and high-pressure lamps with triggers that generate large amounts of heat and pose safety hazards.
4. It is prohibited to install lamps and other electrical equipment on flammable objects that have not been fireproofed or isolated. Electrical equipment that is prone to heat and high-temperature lamps can only be used with the written consent of the exhibition hall. There must be no flammable or flammable items around high-temperature lamps (within 0.5 meters).
5. It is prohibited to aim spotlights and other heating devices at or near fire sprinklers.
6. Any behavior that hinders the normal operation of fire safety and monitoring facilities such as fire alarm contacts, fire hydrants, fire extinguishers, and safety doors is prohibited.
7. No objects or booths should be piled near fire passages and fire hydrants, and no sundries should be piled up within the exhibition hall. Temporary cargo stacking must be centralized, firm and reliable, and overturning and dumping are prohibited.
8. Electrical lines laid in concealed areas should be protected by metal pipes or flame - retardant PVC pipes. Closed light boxes should be installed with ventilation openings sufficient for heat dissipation.
9. It is prohibited to attach or hang any items on ceiling sprinkler devices or lighting devices.
10. Without the written approval of the organizer, various flammable, explosive, toxic, corrosive, radioactive substances, as well as weapons, guns, and knives exhibits shall not be brought into the exhibition hall. If display is required, models must be used instead.
11. Hydrogen balloons are prohibited from use and bringing balloons into the exhibition hall. Once discovered, the organizer has the right to remove them. The removal costs shall be borne by the exhibitors.
12. Matters not covered in these regulations shall be implemented in accordance with the "Shanghai Exhibition Hall Fire Safety Management Standards", "Key Unit Fire Safety Management Requirements" (DB31/540), and "Exhibition Building and Exhibition Fire Prevention Regulations" (DGJ08-2173-2016).